

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180613-EX6009  
**Report Reference** EX4294-19901214  
**Issue Date** 2018-JUNE-13

**Issued to:** BERMAD INC  
9424 W LITTLE YORK RD  
HOUSTON TX 77040-3316

**This is to certify that  
representative samples of**

FIRE PUMP RELIEF VALVES; FIRE PUMP RELIEF VALVES

Fire pump relief valve, Models 730 and 730-R globe and angle \*body patterns in the 2, 2-1/2, 3, 4 and 6 in. sizes for use where the maximum \*relief pressure does not exceed 350 psi.

Fire pump relief valve, Model 730 and 730-R globe and angle body pattern in the 8 in. size for use where the maximum relief pressure does not exceed 175 psi.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL1478, Safety for Fire Pump Relief Valves.  
**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20180613-EX6009  
**Report Reference** EX4294-19901214  
**Issue Date** 2018-JUNE-13

**Issued to:** BERMAD INC  
9424 W LITTLE YORK RD  
HOUSTON TX 77040-3316

**This is to certify that  
representative samples of**

FIRE PUMP RELIEF VALVES; FIRE PUMP RELIEF VALVES

Fire pump relief valve, Models 730 and 730-R globe and angle \*body patterns in the 2, 2-1/2, 3, 4 and 6 in. sizes for use where the maximum \*relief pressure does not exceed 350 psi.


Fire pump relief valve, Model 730 and 730-R globe and angle body pattern in the 8 in. size for use where the maximum relief pressure does not exceed 175 psi.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** NFPA 20, Installation of Stationary Pumps for Fire Protection.


**Additional Information:** See the ULC Online Certification Directory at [www.ulc.ca](http://www.ulc.ca) for additional information

Only those products bearing the ULC Listing Mark should be considered as being covered by ULC's Listing and Follow-Up Service.

The ULC Listing Mark generally includes the following elements: the symbol ULC in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by ULC; and the product category name (product identifier) as indicated in the appropriate ULC Directory.

To confirm the status, validate the above information via the online directory.

Look for the ULC Listing Mark on the product.



Joseph Hosey, General Manager, Director of Sales - Canada

UNDERWRITERS LABORATORIES OF CANADA INC.

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact a local ULC Customer Service Representative at <http://ul.com/aboutul/locations/>

