BERMAD Waterworks

Model WW-720 EN/ES

Engineering Specification

Pressure Reducing Valve Lines:

The pilot controlled Pressure Reducing Valves shall reduce higher upstream pressure to lower, preset, constant downstream pressure regardless of fluctuating demand or varying upstream pressure. The desired downstream pressure shall be easy to set at site, by turning the pilot adjusting screw.

1. Main Valve

- 1.1. The main valve shall be diaphragm actuated oblique ("Y") Globe pattern design.
- 1.2. The valve shall have an unobstructed flow path, with no stem guides, bearings, or supporting ribs.
- 1.3. The valve shall have a replaceable stainless steel seat ring.
- 1.4. The S.S seat ring shall be fitted on a specially designed raised ridge for improved cavitation resistance
- 1.5. The actuator assembly shall be double chambered with an inherent casted separating partition between the lower surface of diaphragm and the main valve.
- 1.6. The standard double chambered actuator assembly shall be capable of simple conversion to single chambered configuration and vice versa while maintaining the valve's overall dimensions: weight, height, length.
- 1.7. The valve shall be center guided by a bearing in the separating partition.
- 1.8. The diaphragm shall not be used as a sealing surface.
- 1.9. The valve diaphragm shall be isolated from the flow through the main valve.
- 1.10. The valve shall be capable of accepting of:
 - Flat type plug for high flow conditions
 - V-Port type plug which changes the ratio of flow to stem travel allowing excellent performance in a wide range of working conditions
 - Cavitation Cage type designed to operate under high differential pressure conditions eliminating cavitation damage
- 1.11. The valve shall be capable of accepting a visual valve position indicator for observing its seal disk opening level.
- 1.12. The valve shall be capable of accepting an electric limit (on-off) switch and position transmitter (0-100% opening)
- 1.13. The valve pressure rating shall be PN16; 250 psi.
- 1.14. Valve flange shall be with flats for vertical support.
- 1.15. Valve "flange to flange" length shall be according to EN 558-1.

2. Construction Materials

The main Valve Construction Material shall be:

- 2.1. Body, cover and separating partition: Cast Ductile Iron.
- 2.2. Internal parts: Stainless Steel, Bronze and Epoxy coated Steel
- 2.3. Diaphragm: nylon fabric-reinforced synthetic rubber.
- 2.4. Seals: Synthetic rubber.
- 2.5. Bolts and nuts: Stainless Steel.

3. Coating

Valve body, cover and separating partition shall have a protective fusion bonded epoxy coating.

- 3.1. Coating type shall be Fusion Bonded Epoxy.
- 3.2. Coating material shall create an effective barrier against wide range of fluids.
- 3.3. Coating color shall be Dark Blue.
- 3.4. Coating thickness shall be 250-500µm.
- 3.5. Coating shall be certified for all major drinking water standards.

4. Control System

- 4.1. Tubing and fittings shall be made of Stainless Steel 316 (1.5" 12"; DN40- 300), Copper & Brass (14"; DN350 and above).
- 4.2. Control accessories including: regulating pilot, filter, needle valves, cock valves etc. shall be made of Bronze, Brass by standard.
- 4.3. Pilot setting range shall be in accordance with the valve pressure rating.
- 4.4. The pilot shall be capable of accommodating various springs for high resolution performance.
- 4.5. The control system shall be equipped with an external "Y" shape filter. Cleaning the filter shall not require isolating the main valve.

5. Service

- 5.1. All valve components shall be accessible and serviceable without removing the valve from the pipeline
- 5.2. The entire actuator assembly (seal disk to top cover) shall be removable from the valve as one integral unit to reduce downtime



BERMAD Waterworks

Model WW-720 EN/ES

Engineering Specification

6. Testing

- 6.1. The valve manufacturer shall have hydraulic test laboratory in his premises, capable of performing both dynamic and static tests of all manufactured valves.
- 6.2. Prior to shipment the valve shall be tested a complete functional test performed under dynamic conditions similar to the project specification

7. Approvals And Certifications

- 7.1. The valve manufacturer quality system shall be certified to ISO 9001-2015
- 7.2. The manufacturer shall be capable of supplying valves certified by major drinking water standards such as: NSF61 (USA), WRAS (UK), SAI (Australia), DVGW (Germany), ACS (France) and others.

