

CERTIFICATE OF PRODUCT AUTHORISATION

(Valid for use on Infrastructure systems within South East Water's licensed district)

Issued to Bermad Water Technologies

SEW Authorisation No: 19/0020	Australian Standard:	AS/NZS 4956:2008
	WSAA Product Appraisal No:	PA 1907
	QMS Certification Reference:	SMK40516
	WSAA Product Specification No:	WSA PS-265
File Ref: 901/101/0696 Vol. 31	Product Authorisation Expiry Date:	22 November 2024

Description of Product

CSA Fox 3F-RFP Combination Air valves for Water Supply systems.

- Ductile Iron bodied combination (double orifice) *
- Size Range: DN25mm, DN50mm, DN80mm, DN100mm, DN150mm, DN200mm and DN250mm *
- Flanged connections available *
- PN16 and PN35 pressure rated *

(*Refer to MRWA web portal for conditions)

Conditions:

1. This Authorisation consent applies only to those items listed in this Certificate and the Melbourne Retail Water Agencies (MRWA) web portal for Water Supply pipeline systems.
2. This Authorisation consent does not refer to the effectiveness of the product and no claim shall be made through advertising, promotion or in any other way that the above products have been authorised or tested by South East Water in other than the terms of this authorisation.
3. The items described above are authorised for use in South East Water's infrastructure systems, in accordance with the design and installation practices as detailed or referenced in the MRWA Edition of the Water Services Association of Australia Water Supply Code of Australia WSA 03 Version 2.0, MRWA Technical Standards, South East Water technical Addendums and installation recommendations provided by the manufacturer.
4. This Authorisation consent is valid for 60 months from the issue date of this certificate. Renewals of approval should be sought 3 months prior to approval expiry.
5. Bermad Water Technologies shall be responsible for assuring the quality of approved products that are supplied to the industry market. Where approved products or parts thereof are manufactured or assembled by a third party, Bermad Water Technologies shall employ systematic procedures to verify product conformance.
6. The product shall be either manufactured or supplied under a third party certified ISO 9001 Quality Assurance Management System or approved equivalent system deemed acceptable by South East Water. All products shall be identified with the manufacturers name or trademark.
7. The products shall demonstrate satisfactory performance when installed on any infrastructure system in South East Water's licensed district.
8. South East Water shall be notified in writing if:
 - The third party ISO 9001 certification is withdrawn, suspended or changed;
 - Any change of the certification agency occurs;
 - There are any changes of product design, materials, model numbers etc; or
 - The products are to be withdrawn from sale.
9. The products may be subjected to random quality control checks for which a charge may apply. Compliance with new Standards as they are replaced will need to be demonstrated.
10. South East Water reserves the right to request additional information and/or evidence of product suitability add or vary to the conditions set out above, or if necessary, modify or withdraw the approval certificate at any time.
11. Neither the Publisher(s) nor any person involved in the preparation of this Certificate and product assessment criteria underlying it accept(s) any liability for any loss or damage suffered by any person however caused (including negligence or the omission by any person to do anything) relating in any way to the Certificate or the product assessment criteria underlying it. This includes (without limitation) any liability for the product authorisation or information in the Certificate or any errors or omissions.

Authorised by: _____



Standards & Products Branch

Date: 22 November 2019